

Exova Warringtonfire Aus Pty Ltd
 Unit 2, 409-411 Hammond Road
 Dandenong, Victoria 3175
 Australia

T: +61 (0)3 9767 1066
 F: +61 (0)3 9767 1001
 E: market.pacific@exova.com
 W: www.exova.com



Postal Address:
 PO Box 4282
 Dandenong South, Victoria 3164
 Australia

Testing. Advising. Assuring.

EWFA CERTIFICATE OF TEST	CERTIFICATE No : SFC 2830900.1	Page 1 of 1
---------------------------------	---------------------------------------	--------------------

Report Sponsor	Certificate Issue Date
Unitex Granular Marble Pty Ltd 22 Park Drive Dandenong, VIC, 3175	13/05/13

Introduction

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 2830900.2	12/04/2013	AS1530.8.1-2007



Description of Product		
Product name	Test Specimen Arrangement	Rating
Unitex® Base Board® Wall System	The wall system consisted of two 90x45 timber stud frames, the central frame offset 310mm back incorporating an 800mm x 800mm aluminium framed window and eaves detail. The unexposed side was faced with 10mm Gyprock plasterboard while the exposed side had a nominally 17.5mm Unitex® Render system applied over 78mm thick Base Board® Sheets.	BAL A-40

Notes

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
Phone / Fax	+61 (0) 3 9767 1066 / +61 (0) 3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  S. J. Halliday	Reviewed By:  C. M. McLean